
PXle-7890/7891

Getting Started

2025-07-23



Contents

PXle-7890/7891 Getting Started.....	3
Unpacking the Kit	4
What You Need to Get Started	5
Front Panel and Connectors.....	9
Connector Pinouts	11
Preparing the Environment	19
Installing the PXle-7890/7891 Module	20
Installing the Hot Pluggable QSFP Module	22
Installing the Software.....	23
Configuring the PXle-7890/7891 in MAX.....	24
Troubleshooting	25
What Should I Do if the PXle-7890/7891 Does Not Appear in MAX?.....	25
What Should I Do if the PXle-7890/7891 Fails the Self-Test?.....	25
What Should I Do if the AO Channel on Connector 3 (LLAO) Is Not Operational	26
Why Does DC Voltage Remain at the AO Channel When Connector 3 (LLAO) is Shut Down in Over-Temperature Condition?	26
What Should I Do if the Driver Returns Power Shutdown Status to Prevent Excessive Power Consumption?	26

PXle-7890/7891 Getting Started



Note Before you begin, install and configure your chassis and controller.

This document explains how to install, configure, and troubleshoot the PXle-7890 or PXle-7891 module. You can program the PXle-7890/7891 with the following software options.

- NI-FlexRIO driver software
- NI LabVIEW Instrument Design Libraries for FlexRIO (instrument design libraries)



Note Adapter modules are not installable or interchangeable on the PXle-7890/7891 device.

Unpacking the Kit



Notice To prevent electrostatic discharge (ESD) from damaging the module, ground yourself using a grounding strap or by holding a grounded object, such as your computer chassis.

1. Touch the antistatic package to a metal part of the computer chassis.
2. Remove the module from the package and inspect it for loose components or other signs of damage.



Notice Never touch the exposed pins of connectors.



Note Do not install a module if it appears damaged in any way.

3. Unpack any other items and documentation from the kit.


Store the module in the antistatic package when the module is not in use.

What You Need to Get Started

Kit Contents

Verify that the following items are included in the PXIe-7890/7891 kit.

- PXIe-7890 or PXIe-7891 module.



- ***PXIe-7890 or PXIe-7891 Safety, Environmental, and Regulatory Information*** document.

Recommended Cables

NI recommends the following cables for use with the PXIe-7890/7891.

Connector	Cable	Description	Part Number
CONNECTOR 0 and CONNECTOR 4	SHC68-C68-D4	68-Pin, Male VHDCI to 68-Pin, Male VHDCI, 50 Ω , Shielded Digital Cable	781013-01 (0.55 m) 196275-01 (1 m) 781293-01 (2 m)
	SHC68-2MDR26- RDIO2 ^[1]	R Series Digital Cable, 1 m	148709-01 (1 m)
	SHC68-C68- RDIO2 ^[2]	68-PinVHDCI Male to 68-Pin VHDCI Male, 80 MHz, Shielded Digital Cable	156166-01 (1 m) 156166-02 (2 m)
CONNECTOR 1 and CONNECTOR 3	SHC68-C68-D4 ^[3]	68-Pin, Male VHDCI to 68-Pin, Male VHDCI, 50 Ω , Shielded Digital Cable	781013-01 (0.55 m) 196275-01 (1 m) 781293-01 (2 m) 132625-03 (3 m)
	SHC68- 2MDR26-RDIO2 ^[1]	R Series Digital Cable, 1 m	148709-01 (1 m)

Connector	Cable	Description	Part Number
	SHC68-C68-RDIO2 ^[2]	68-Pin VHDCI Male to 68-Pin VHDCI Male, 80 MHz, Shielded Digital Cable	156166-01 (1 m) 156166-02 (2 m)
CONNECTOR 2	SHC68-C68-D3	68-Pin, male VHDCI to 68-Pin, male VHDCI, 100 ohm, double- shielded LVDS cable	188143-01 (1 m)
^[1] To be used together with a Read Transition Interface (RTI-12307) in a Switch Load and Signal Conditioning (SLSC) system. ^[2] To be used together with a Read Transition Interface (RTI-12301) in an SLSC system. ^[3] Used for Connector 3 when the load side is terminated with 50 Ω.			

Recommended Accessories


NI recommends the following accessories for use with the PXIe-7890/7891.

Connector	Accessory	Description	Part Number
CONNECTOR 0 and CONNECTOR 4	SCB-68 HSDIO	Screw Terminal, 68-pin VHDCI, Shielded I/O Connector Block	782914-01
CONNECTOR 1 and CONNECTOR 3	SMB-2153	32-Channel, 1-Pin SMB, 68-Pin VHDCI, Breakout Connector Block	782648-01
	SCB-68	Screw Terminal, 68-pin VHDCI, Shielded I/O	782914-01

Connector	Accessory	Description	Part Number
	HSDIO	Connector Block	
CONNECTOR 2	SMB-2145 ^[1]	1-Pin SMB, 68-pin VHDCI, 16-Channel Analog Input, NI-5752 Terminal Block	781516-01
^[1] The negative analog input will be connected to the common ground GND of the module.			

Front Panel and Connectors

Figure 1. PXIe-7890 and 7891 Front Panels



The following table describes the signal connections for the PXIe-7890 and PXIe-7891.

Table 1. Front Panel Connector Descriptions and Functions

Connector	Description	Function
PORT 0 and PORT 1	QSFP connector, SFF-8436 compliant	High-speed serial interfacing port
CONNECTOR 0 and CONNECTOR 4	68-pin VHDCI receptacle	Digital IO
CONNECTOR 1		Analog Output
CONNECTOR 2		Analog Input

Connector	Description	Function
CONNECTOR 3		Low-latency analog output

Connector Pinouts

PORT 0 and PORT 1

[Figure 1](#) shows the pinout for the PXIe-7890/7891 PORT 0 and PORT 1 connectors, followed by pin descriptions.

Figure 1. QSFP Connector Pinout

GND	20	19	GND
Rx2n	21	18	Rx1n
Rx2p	22	17	Rx1p
GND	23	16	GND
Rx4n	24	15	Rx3n
Rx4p	25	14	Rx3p
GND	26	13	GND
ModPrsL	27	12	SDA
IntL	28	11	SCL
Vcc Tx	29	10	Vcc Rx
Vcc1	30	9	ResetL
LPMode	31	8	ModSelL
GND	32	7	GND
Tx3p	33	6	Tx4p
Tx3n	34	5	Rx4n
GND	35	4	GND
Tx1p	36	3	Tx2p
Tx1n	37	2	Tx2n
GND	38	1	GND

Table 2. Pin Descriptions for PORT 0 and PORT 1 Connectors

Pin	Description
Txn <1..4>	Transmitter Inverted Data Input
Txp <1..4>	Transmitter Non-Inverted Data Input
Rxn <1..4>	Receiver Inverted Data Output
Rxp <1..4>	Receiver Non-Inverted Data Output
SCL	2-Wire Serial Interface Clock

Pin	Description
SDA	2-Wire Serial Interface Data
ModPrsL	Module Present
ModSelL	Module Select
ResetL	Module Reset
IntL	Interrupt
LPMode	Low Power Mode
Vcc Rx	+3.3 V Power Supply Receiver
Vcc Tx	+3.3 V Power Supply Transmitter
Vcc1	+3.3 V Power Supply
GND	Ground



Notice The maximum input signal levels are valid only when the module is powered on. To avoid permanent damage to the PXIe-7890/7891, do not apply a signal to the device when the module is powered down.



Notice Connections that exceed any of the maximum ratings of any connector on the PXIe-7890/7891 can damage the device and the system. NI is not liable for any damage resulting from such connections.

CONNECTOR 0 and CONNECTOR 4

[Figure 2](#) shows the pinouts for PXIe-7890/7891 CONNECTOR 0 and CONNECTOR 4, followed by pin descriptions.

Figure 1. Digital I/O (DIO) Connectors

Connector 0			Connector 4		
GND	68	34	GND		
EXTCLKIN	67	33	GND		
GND	66	32	GND		
DIO0	65	31	DIO1		
GND	64	30	GND		
DIO2	63	29	DIO3		
GND	62	28	GND		
DIO4	61	27	DIO5		
GND	60	26	GND		
DIO6	59	25	DIO7		
GND	58	24	GND		
DIO8	57	23	DIO9		
GND	56	22	GND		
DIO10	55	21	DIO11		
GND	54	20	GND		
DIO12	53	19	DIO13		
GND	52	18	GND		
DIO14	51	17	DIO15		
GND	50	16	GND		
DIO16	49	15	DIO17		
GND	48	14	GND		
DIO18	47	13	DIO19		
GND	46	12	GND		
DIO20	45	11	DIO21		
GND	44	10	GND		
DIO22	43	9	DIO23		
GND	42	8	GND		
DIO24	41	7	DIO25		
GND	40	6	GND		
DIO26	39	5	DIO27		
GND	38	4	GND		
DIO28	37	3	DIO29		
GND	36	2	GND		
DIO30	35	1	DIO31		

Table 3. Pin Descriptions for CONNECTOR 0 and CONNECTOR 4

Pin	Description	Signal Name in LabVIEW
DIO <0..31>	Bidirectional digital input/output signal connection	Digital Input: - Conn0 DI / Ch <0..31> - Conn4 DI / Ch <0..31> Digital Output:

Pin	Description	Signal Name in LabVIEW
		- Conn0 DO / Ch <0..31> - Conn4 DO / Ch <0..31>
EXTCLKIN	External clock input source that can be used for source synchronous acquisitions; the provided clock source must be stable and glitch free	Conn 0 External Clock Conn 4 External Clock
GND	Ground reference for digital signals	—
NC	No connection	—

CONNECTOR 1 and CONNECTOR 3

[Figure 3](#) and [Figure 4](#) show the pinout information for CONNECTOR 1 and CONNECTOR 3. The AO connectors are identical on each device, but differ between modules. Pin descriptions are described in the table below the pinout diagrams.

Figure 1. PXIe-7890 Analog Output (AO)

Figure 1. PXIe-7891 Analog Output (AO)

Connectors

NC	1	35	NC
GND	2	36	GND
NC	3	37	NC
GND	4	38	GND
NC	5	39	NC
GND	6	40	GND
NC	7	41	NC
GND	8	42	GND
NC	9	43	NC
GND	10	44	GND
NC	11	45	NC
GND	12	46	GND
NC	13	47	NC
GND	14	48	GND
NC	15	49	NC
GND	16	50	GND
AO15	17	51	AO14
GND	18	52	GND
AO13	19	53	AO12
GND	20	54	GND
AO11	21	55	AO10
GND	22	56	GND
AO9	23	57	AO8
GND	24	58	GND
AO7	25	59	AO6
GND	26	60	GND
AO5	27	61	AO4
GND	28	62	GND
AO3	29	63	AO2
GND	30	64	GND
AO1	31	65	AO0
GND	32	66	GND
NC	33	67	NC
GND	34	68	GND

Connectors

AO31	1	35	AO30
GND	2	36	GND
AO29	3	37	AO28
GND	4	38	GND
AO27	5	39	AO26
GND	6	40	GND
AO25	7	41	AO24
GND	8	42	GND
AO23	9	43	AO22
GND	10	44	GND
AO21	11	45	AO20
GND	12	46	GND
AO19	13	47	AO18
GND	14	48	GND
AO17	15	49	AO16
GND	16	50	GND
AO15	17	51	AO14
GND	18	52	GND
AO13	19	53	AO12
GND	20	54	GND
AO11	21	55	AO10
GND	22	56	GND
AO9	23	57	AO8
GND	24	58	GND
AO7	25	59	AO6
GND	26	60	GND
AO5	27	61	AO4
GND	28	62	GND
AO3	29	63	AO2
GND	30	64	GND
AO1	31	65	AO0
GND	32	66	GND
NC	33	67	NC
GND	34	68	GND

Table 4. Pin Descriptions for CONNECTOR 1 and CONNECTOR 3

Pin	Description	Signal Name in LabVIEW
AO <0..15> (PXle-7890) AO <0..31> (PXle-7891)	Analog output signal connection	PXle-7890: • Calibrated: Conn1 AO / Ch <0..15> • Calibrated: Conn3 AO / Ch <0..15> • Uncalibrated: Conn1 AO

Pin	Description	Signal Name in LabVIEW
		Raw / Ch <0..15> - Uncalibrated: Conn3 AO Raw / Ch <0..15> PXIe-7891: - Calibrated: Conn1 AO / Ch <0..31> - Calibrated: Conn3 AO / Ch <0..31> - Uncalibrated: Conn1 AO Raw / Ch <0..31> - Uncalibrated: Conn3 AO Raw / Ch <0..31>
GND	Ground reference for the analog output signal	—
NC	No Connection	—

CONNECTOR 2

[Figure 5](#) and [Figure 6](#) show the pinout information for CONNECTOR 2, the analog input VHDCI front panel connector. Pin descriptions are described in the table below the pinout diagrams.

Figure 1. PXIe-7890 Analog Input (AI) VHDCI

Figure 1. PXIe-7891 Analog Input (AI) VHDCI

Connector

GND	1	35	GND
AI0+	2	36	GND
AI0-	3	37	AI1+
GND	4	38	AI1-
AI2+	5	39	GND
AI2-	6	40	AI3+
GND	7	41	AI3-
AI4+	8	42	GND
AI4-	9	43	AI5+
GND	10	44	AI5-
AI6+	11	45	GND
AI6-	12	46	AI7+
GND	13	47	AI7-
NC	14	48	GND
NC	15	49	NC
GND	16	50	NC
NC	17	51	GND
NC	18	52	NC
GND	19	53	NC
NC	20	54	GND
NC	21	55	NC
GND	22	56	NC
NC	23	57	GND
NC	24	58	NC
GND	25	59	NC
GND	26	60	GND
GND	27	61	GND
GND	28	62	GND
GND	29	63	GND
GND	30	64	GND
GND	31	65	GND
GND	32	66	GND
GND	33	67	GND
GND	34	68	GND

Connector

GND	1	35	GND
AI0+	2	36	GND
AI0-	3	37	AI1+
GND	4	38	AI1-
AI2+	5	39	GND
AI2-	6	40	AI3+
GND	7	41	AI3-
AI4+	8	42	GND
AI4-	9	43	AI5+
GND	10	44	AI5-
AI6+	11	45	GND
AI6-	12	46	AI7+
GND	13	47	AI7-
AI8+	14	48	GND
AI8-	15	49	AI9+
GND	16	50	AI9-
AI10+	17	51	GND
AI10-	18	52	AI11+
GND	19	53	AI11-
AI12+	20	54	GND
AI12-	21	55	AI13+
GND	22	56	AI13-
AI14+	23	57	GND
AI14-	24	58	AI15+
GND	25	59	AI15-
GND	26	60	GND
GND	27	61	GND
GND	28	62	GND
GND	29	63	GND
GND	30	64	GND
GND	31	65	GND
GND	32	66	GND
GND	33	67	GND
GND	34	68	GND

Table 5. Pin Descriptions for CONNECTOR 2

Pin	Description	Signal Name in LabVIEW
AI <0+...7+> (PXIe-7890)	Positive analog input signal connection	PXIe-7890: • Calibrated: Conn2 AI / Ch <0..7> • Uncalibrated: Conn2 AI / Ch <0..7>
AI <0+...15+> (PXIe-7891)		
AI <0-...7-> (PXIe-7890)	Negative analog input signal connection	

Pin	Description	Signal Name in LabVIEW
AI <0-...15-> (PXIe-7891)		PXIe-7891: • Calibrated: Conn2 AI / Ch <0..15> • Uncalibrated:Conn2 AI / Ch <0..15>
GND	Ground reference for the analog input signal	—
NC	No connection	—

Preparing the Environment

Ensure that the environment you are using the PXIe-7890 in meets the following specifications.

Temperature	
Operating	0 °C to 55 °C
Storage	-40 °C to 71 °C
Humidity	
Operating	10% to 90%, noncondensing
Storage	5% to 95%, noncondensing
Pollution Degree	2
Maximum altitude	2,000 m (800 mbar) (at 25 °C ambient temperature)



Notice This device is intended for use in indoor applications only.




Note Refer to the device specifications on ni.com/manuals for complete specifications.

Installing the PXIe-7890/7891 Module

This section contains instructions for installing the PXIe-7890 or PXIe-7891 module in a PXI Express chassis. Refer to your chassis user manual for specific instructions and warnings. To install the module, complete the following steps:

1. Connect the AC power source to the PXI Express chassis before installing the module. The AC power cord grounds the chassis and protects it from electrical damage while you install the module.
2. Ensure that the chassis is powered off.
3. Inspect the slot pins on the chassis backplane for any bends or damage prior to installation. Do not install any module if the backplane is damaged.
4. Remove the black plastic covers from all the captive screws on the module front panel.
5. Touch any metal part of the chassis to discharge static electricity.
6. Place the module edges into the module guides at the top and bottom of the chassis, as shown in the following figure. Slide the module into the slots until it is fully inserted. Slide the module to the rear of the chassis, making sure that the injector/ejector handle is pushed down.

Figure 1. Installing the Module



1. Injector/Ejector Handle 2. PXIe-7890/7891 Module 3. Front Panel Mounting Screws (2x) 4. PXI Express Chassis 5. Module Guides

7. When you begin to feel resistance, push up on the injector/ejector handle to fully

seat the module into the chassis frame. Secure the module front panel to the chassis using the module front-panel mounting screws.




Note Tightening the top and bottom mounting screws increases mechanical stability and also electrically connects the front panel to the chassis, which can improve the signal quality and electromagnetic performance.

8. Cover all empty slots using EMC filler panels or fill using slot blockers to maximize cooling air flow, depending on your application.
9. Leave the chassis powered off until you have installed the PXIe-7890 or PXIe-7891 module.

Installing the Hot Pluggable QSFP Module

1. Hold the QSFP module with the pull-tab facing the left.
2. Remove the protective cover from the opposite end of the pull-tab. Leave the dust plug inserted in the pull-tab end.

Figure 1. QSFP Module Install



3. With the pull-tab facing the left, align the QSFP module with the socket opening at PORT 0 or PORT 1 on the PXIe-7890/7891. Carefully slide the QSFP module into the port.
4. Use your thumb to press firmly on the QSFP module until it fully seats into PORT 0 or PORT 1.



Note The QSFP module must be fully seated in PORT 0 or PORT 1 for the PXIe-7890/7891 to detect a connection.

5. Power on the chassis.

To protect the QSFP module from dust and debris, NI recommends leaving the dust plug inserted in the pull-tab end of the module until you are ready to connect a cable.

Installing the Software

You must be an Administrator to install NI software on your computer.

1. Install an ADE, such as LabVIEW or LabWindows™/CVI™.
2. Download the driver software installer from ni.com/downloads.
NI Package Manager downloads with the driver software to handle the installation. Refer to the NI Package Manager Manual for more information about installing, removing, and upgrading NI software using NI Package Manager.
3. Follow the instructions in the installation prompts.



Note Windows users may see access and security messages during installation. Accept the prompts to complete the installation.

4. When the installer completes, select **Restart** in the dialog box that prompts you to restart, shut down, or restart later.



Note Install LabVIEW FPGA Compilation Tool for Vivado if you want to use the local compile server to compile a LabVIEW FPGA bit file.

Configuring the PXIe-7890/7891 in MAX

Use Measurement & Automation Explorer (MAX) to configure your NI hardware. MAX informs other programs about which NI hardware products are in the system and how they are configured. MAX is automatically installed with FlexRIO.

1. Launch MAX.
2. In the configuration tree, expand **Devices and Interfaces** to see the list of installed NI hardware.
Installed modules appear under the name of their associated chassis.
3. Expand your **Chassis** tree item.
MAX lists all modules installed in the chassis. Your default names may vary.



Note If you do not see your module listed, press <F5> to refresh the list of installed modules. If the module is still not listed, power off the system, ensure the module is correctly installed, and restart.

4. Record the identifier MAX assigns to the hardware. Use this identifier when programming the PXIe-7890/7891.
5. Self-test the hardware by selecting the item in the configuration tree and clicking **Self-Test** in the MAX toolbar.
The MAX self-test performs a basic verification of hardware resources.

Troubleshooting

If an issue persists after you complete a troubleshooting procedure, search our KnowledgeBase for additional information our technical support engineers create as they answer common user questions and resolve unexpected issues.

What Should I Do if the PXIe-7890/7891 Does Not Appear in MAX?

1. In the MAX configuration tree, expand **Devices and Interfaces**.
2. Expand the **Chassis** tree to see the list of installed hardware, and press <F5> to refresh the list.
3. If the module is still not listed, power off the system, ensure that all hardware is correctly installed, and restart the system.
4. Navigate to the Device Manager by right-clicking the Start button, and selecting **Device Manager**.
5. Verify the PXIe-7890/7891 appears in the Device Manager.
 - a. Under an NI entry, confirm that a PXIe-7890/7891 entry appears.



Note If you are using a PC with a device for PXI remote control system, under **System Devices**, also confirm that no error conditions appear for the **PCI-to-PCI Bridge**.

- b. If error conditions appear, reinstall the PXIe-7890/7891 driver.

What Should I Do if the PXIe-7890/7891 Fails the Self-Test?

1. Restart the system.
2. Launch MAX.
 - Failed self-test Perform self-calibration, then perform the self-test again. The PXIe-7890/7891 must be calibrated to pass the self-test.
 - Failed self-calibration Perform self-calibration again.
3. Power off the chassis.

4. Reinstall the failed module in a different slot.
5. Power on the chassis
6. Perform the self-test again.

What Should I Do if the AO Channel on Connector 3 (LLAO) Is Not Operational

1. Check for an error returned in the IO Error node: **304335** (**NIFLEXRIO_Status_AnalogOutputShutdown**). This error indicates that the output channel(s) is shut down to protect against excessive power consumption or temperature. Check the status of analog output channel(s) to determine which channel(s) is shut down. Download the bit file again to restore normal operation of analog output channel(s).
2. Check if there is any fault condition on the IO pins connection.
3. Make sure the chassis cooling fan is still functional.
4. Restart the Test VI to reset the module.

Why Does DC Voltage Remain at the AO Channel When Connector 3 (LLAO) is Shut Down in Over-Temperature Condition?

Up to 3.5 V of residue voltage may remain on Connector 3, depending on the AO configuration on dual output range channels before the shutdown occurs. This is not a hardware issue, but if it occurs, you can reset the module through the Test VI and power up again to reset all channels to default 0 V output.

What Should I Do if the Driver Returns Power Shutdown Status to Prevent Excessive Power Consumption?

1. Check for an error returned in the IO Error node: **-304313** (**NIFLEXRIO_Status_PowerShutdown**). This error indicates that the device has shut down to protect against excessive power consumption. Check airflow and cooling, and download the bit file again. To avoid this error, monitor the power consumption, power shutdown threshold, and margin of the device. If

necessary, reduce FPGA power consumption.

2. Check the air flow and cooling of the PXI chassis.
3. Restart the Test VI to reset the module.
4. Monitor the power consumption and power shutdown threshold.
5. If power is near to the power shutdown threshold, reduce the power consumption from AO or FPGA.