

## COMPREHENSIVE SERVICES

We offer competitive repair and calibration services, as well as easily accessible documentation and free downloadable resources.

## SELL YOUR SURPLUS

We buy new, used, decommissioned, and surplus parts from every NI series. We work out the best solution to suit your individual needs.

 Sell For Cash    Get Credit    Receive a Trade-In Deal

## OBSOLETE NI HARDWARE IN STOCK & READY TO SHIP

We stock **New**, **New Surplus**, **Refurbished**, and **Reconditioned** NI Hardware.



*Bridging the gap between the manufacturer and your legacy test system.*

 1-800-915-6216

 [www.apexwaves.com](http://www.apexwaves.com)

 [sales@apexwaves.com](mailto:sales@apexwaves.com)

*All trademarks, brands, and brand names are the property of their respective owners.*

**Request a Quote**

 **CLICK HERE**


**cRIO-9081**

## GETTING STARTED GUIDE

# NI cRIO-9082

Reconfigurable Embedded Chassis with Integrated Intelligent Real-Time Controller for CompactRIO

This document describes how to begin using the National Instruments cRIO-9082.



## Safety Guidelines

---



**Caution** Do not operate the cRIO-9082 in a manner not specified in this document. Product misuse can result in a hazard. You can compromise the safety protection built into the product if the product is damaged in any way. If the product is damaged, return it to NI for repair.

## Safety Guidelines for Hazardous Locations

The cRIO-9082 is suitable for use in Class I, Division 2, Groups A, B, C, D, T4 hazardous locations; Class I, Zone 2, AEx nA IIC T4 and Ex nA IIC T4 hazardous locations; and nonhazardous locations only. Follow these guidelines if you are installing the cRIO-9082 in a

potentially explosive environment. Not following these guidelines may result in serious injury or death.



**Caution** Do not disconnect the power supply wires and connectors from the controller unless power has been switched off.



**Caution** Do not disconnect I/O-side wires or connectors unless power has been switched off or the area is known to be nonhazardous.



**Caution** Do not remove modules unless power has been switched off or the area is known to be nonhazardous.



**Caution** Substitution of components may impair suitability for Class I, Division 2.




**Caution** For Division 2 and Zone 2 applications, install the system in an enclosure rated to at least IP54 as defined by IEC/EN 60079-15.



**Caution** The USB port requires the NI Industrial USB Drive with Retention Screw (780717-xxxx) for hazardous locations. Do not disconnect a drive unless the cRIO-9082 is powered off or the area is known to be nonhazardous.

## Special Conditions for Hazardous Locations Use in Europe and Internationally

The cRIO-9082 has been evaluated as Ex nA IIC T4 Gc equipment under DEMKO 07 ATEX 0626664X and is IECEx UL 14.0089X certified. Each device is marked  II 3G and is suitable for use in Zone 2 hazardous locations, in ambient temperatures of  $0\text{ }^{\circ}\text{C} \leq T_a \leq 55\text{ }^{\circ}\text{C}$ .



**Caution** You must make sure that transient disturbances do not exceed 140% of the rated voltage.



**Caution** The system shall only be used in an area of not more than Pollution Degree 2, as defined in IEC/EN 60664-1.



**Caution** The system shall be mounted in an ATEX/IECEx-certified enclosure with a minimum ingress protection rating of at least IP54 as defined in IEC/EN 60079-15.



**Caution** The enclosure must have a door or cover accessible only by the use of a tool.

## Electromagnetic Compatibility Guidelines

---

This product was tested and complies with the regulatory requirements and limits for electromagnetic compatibility (EMC) stated in the product specifications. These requirements and limits provide reasonable protection against harmful interference when the product is operated in the intended operational electromagnetic environment.

This product is intended for use in industrial locations. However, harmful interference may occur in some installations, when the product is connected to a peripheral device or test object, or if the product is used in residential or commercial areas. To minimize interference with radio and television reception and prevent unacceptable performance degradation, install and use this product in strict accordance with the instructions in the product documentation.

Furthermore, any changes or modifications to the product not expressly approved by National Instruments could void your authority to operate it under your local regulatory rules.



**Caution** To ensure the specified EMC performance, operate this product only with shielded cables and accessories.

## Special Conditions for Marine Applications

Some products are Lloyd's Register (LR) Type Approved for marine (shipboard) applications. To verify Lloyd's Register certification for a product, visit [ni.com/certification](https://ni.com/certification) and search for the LR certificate, or look for the Lloyd's Register mark on the product.



**Caution** In order to meet the EMC requirements for marine applications, install the product in a shielded enclosure with shielded and/or filtered power and input/output ports. In addition, take precautions when designing, selecting, and installing measurement probes and cables to ensure that the desired EMC performance is attained.

## Preparing the Environment

---

Ensure that the environment in which you are using the cRIO-9082 meets the following specifications.

Operating temperature (IEC 60068-2-1, IEC 60068-2-2)	0 °C to 55 °C
Operating humidity (IEC 60068-2-56)	10% RH to 90% RH, noncondensing
Pollution Degree	2
Maximum altitude	2,000 m

Indoor use only.



**Note** Refer to the device specifications on [ni.com/manuals](https://ni.com/manuals) for complete specifications.

## Unpacking the Kit

---



**Caution** To prevent electrostatic discharge (ESD) from damaging the device, ground yourself using a grounding strap or by holding a grounded object, such as your computer chassis.

1. Touch the antistatic package to a metal part of the computer chassis.
2. Remove the device from the package and inspect the device for loose components or any other sign of damage.



**Caution** Never touch the exposed pins of connectors.



**Note** Do not install a device if it appears damaged in any way.

3. Unpack any other items and documentation from the kit.

Store the device in the antistatic package when the device is not in use.


## Verifying the Kit Contents

---

Verify that the following items are included in the cRIO-9082 kit.

**Figure 1. cRIO-9082 Kit Contents**

---



- 
1. cRIO Device with Power Connector
  2. Ferrite

3. cRIO Device Drivers Media
  4. Getting Started Guide
- 

## Installing Software on the Host Computer

---

Before using the cRIO-9082, you must install the following application software and device drivers on the host computer in this order:

1. LabVIEW 2011 or later
2. LabVIEW Real-Time Module 2011 or later<sup>1</sup>
3. LabVIEW FPGA Module 2011 or later<sup>2</sup>
4. NI CompactRIO Device Drivers 4.0 or later

For minimum software support information, visit [ni.com/info](http://ni.com/info) and enter the Info Code `swwsupport`.

---


<sup>1</sup> LabVIEW Real-Time Module is only required when using a Real-Time cRIO-9082.

<sup>2</sup> LabVIEW FPGA Module is not required when using Scan Interface mode. To program the user-accessible FPGA on the cRIO-9082, LabVIEW FPGA Module is required.

# Installing C Series Modules

---

Complete the following steps to install a C Series module.



1. Verify that power is not connected to the I/O connector(s) on the C Series module. If the system is in a nonhazardous location, the cRIO-9082 can be powered on when you install modules.
2. Press the latches on the C Series module.
3. Align the C Series module with a slot and seat it in the slot until the latches lock in place.


## Removing C Series Modules

Verify that power is not connected to the I/O connector(s) on the C Series module before you remove a module from the cRIO-9082. If the system is in a nonhazardous location, the cRIO-9082 can be powered on when you remove modules.

## Connecting the cRIO-9082

---

The cRIO-9082 has the following connectors, LEDs, and buttons.



- |                                 |                          |
|---------------------------------|--------------------------|
| 1. LEDs                         | 8. MXI Express Connector |
| 2. Power Connector              | 9. VGA Video Connector   |
| 3. RJ-50 RS-485 Serial Port     | 10. RS-232 Serial Port   |
| 4. Grounding Screw              | 11. Power Button         |
| 5. USB Ports 1-4                | 12. Reset Button         |
| 6. USB Retention Standoff       | 13. DIP Switches         |
| 7. RJ-45 Ethernet Ports 1 and 2 |                          |

## Connecting the cRIO-9082 to Ground

You must connect the cRIO-9082 grounding terminal to the grounding electrode system of the facility.

### What to Use

- Ring lug
- Wire, 1.6 mm<sup>2</sup> (14 AWG) or larger
- Screwdriver, Phillips #2

### What to Do

Complete the following steps to ground the cRIO-9082.

1. Attach the ring lug to the wire.
2. Remove the grounding screw from the grounding terminal on the cRIO-9082.
3. Attach the ring lug to the grounding terminal.
4. Tighten the grounding screw to 0.5 N · m (4.4 lb · in.) of torque.
5. Attach the other end of the wire to the grounding electrode system of your facility using a method that is appropriate for your application.



**Caution** If you use shielded cabling to connect to a C Series module with a plastic connector, you must attach the cable shield to the chassis grounding terminal using 1.6 mm<sup>2</sup> (14 AWG) or larger wire. Attach a ring lug to the wire and attach the wire to the chassis grounding terminal. Solder the other end of the wire to the cable shield. Use shorter wire for better EMC performance.

For more information about ground connections, visit [ni.com/info](https://ni.com/info) and enter the Info Code `emcground`.

## Connecting the cRIO-9082 to Power

The cRIO-9082 requires a 9 V to 30 V external power supply. The cRIO-9082 filters and regulates the supplied power and provides power for the C Series modules. The cRIO-9082 has a primary power input, V1, and a secondary power input, V2.

The POWER LED on the cRIO-9082 indicates which power input is in use, as shown in the following table.

**Table 1.** POWER LED Indicators

LED Color	LED Pattern	Indication
Green	Solid	The cRIO-9082 is powered from the V1 input.
Yellow	Solid	The cRIO-9082 is powered from the V2 input.
—	Off	The cRIO-9082 is powered off.



**Caution** Do not connect V2 to a DC mains supply or to any supply that requires a connecting cable longer than 3 m (10 ft). A DC mains supply is a local DC electricity supply network in the infrastructure of a site or building.

### What to Use

- Ferrite
- Screwdriver, 2.54 mm (0.10 in.) flathead
- Primary power supply, 9 V to 30 V, 46 W minimum
- (Optional) Secondary power supply, 9 V to 30 V, 46 W minimum

NI recommends the power supplies listed in the following table for the cRIO-9082.



**Table 2.** NI Power Supplies


Power Supply	Part Number
NI PS-15 Industrial Power Supply (24 VDC, 5 A, 100 VAC to 120 VAC/200 VAC to 240 VAC input)	781093-01
NI PS-10 Desktop Power Supply (24 VDC, 5 A, 100 VAC to 120 VAC/200 VAC to 240 VAC input)	782698-01



## What to Do

Complete the following steps to connect a power supply to the cRIO-9082.

1. Ensure that your power supply is powered off.
2. Install the ferrite on the negative and positive leads of the power supply, as shown in the following figure.

**Figure 2.** Installing a Ferrite on the Power Leads



1. Pass the leads through the ferrite twice, leaving 50 mm to 75 mm (2 in. to 3 in.) between the ferrite and the end of the leads.
  2. Close the ferrite around the leads.
3. Remove the power connector from the cRIO-9082.
    -  **Caution** Do not tighten or loosen the terminal screws on the power connector while the cRIO-9082 is powered on.
  4. Connect the primary power supply and optional secondary power supply to the power connector.
    -  **Note** The C terminals are internally connected to each other.
  5. Tighten the terminal screws on the power connector to 0.20 N · m to 0.25 N · m (1.8 lb · in. to 2.2 lb · in.) of torque.
  6. Install the power connector on the front panel of the cRIO-9082.
  7. Tighten the power connector screw flanges to 0.20 N · m to 0.25 N · m (1.8 lb · in. to 2.2 lb · in.) of torque.
  8. Power on the primary power supply and optional secondary power supply.

## Powering On the cRIO-9082

To power on the cRIO-9082, ensure that the power source is turned on and press the power button on the front panel of the cRIO-9082. You can use the cRIO-9082 BIOS setup utility to configure the cRIO-9082 to start immediately when power is applied or to respond to the front-panel power button. Refer to the device user manual on [ni.com/manuals](http://ni.com/manuals) for information about the different powerup behaviors you can configure. The power button is enabled by default so that the cRIO-9082 does not power on until the power button is pressed. When the cRIO-9082 powers on, the Power LED turns on and the controller runs a power-on self test (POST).

When the POST is complete, the operating system is loaded and the cRIO-9082 is ready for use. The cRIO-9082 as shipped either includes a pre-installed operating system such as Windows, or has the hard drive partitioned for LabVIEW Real-Time. In order for the system to boot into LabVIEW Real-Time, the DISABLE RT DIP switch must be in the OFF position. In order for the system to boot into any other operating system, the DISABLE RT DIP switch must be in the ON position. Refer to the device user manual on [ni.com/manuals](http://ni.com/manuals) for more information about the DIP switches.

## Connecting the cRIO-9082 to a Network

Connect the cRIO-9082 to an Ethernet network using RJ-45 Ethernet port 1 on the controller front panel. Use a standard Category 5 (CAT-5) or better shielded, twisted-pair Ethernet cable to connect the cRIO-9082.



**Note** To prevent data loss and to maintain the integrity of your Ethernet installation, do not use a cable longer than 100 m.

For Windows systems, the network behavior is determined by the Windows network drivers.

For RT systems, the cRIO-9082 attempts to initiate a DHCP network connection at powerup. If the cRIO-9082 is unable to obtain an IP address, it connects to the network with a link-local IP address with the form `169.254.x.x`.

After powerup, you can install software on the cRIO-9082. For RT systems, you can also change the network settings using Measurement & Automation Explorer (MAX) on a host computer.



**Note** Installing software may change the network behavior of the cRIO-9082. For information about network behavior by installed software version, go to [ni.com/info](http://ni.com/info) and enter the Info Code `ipconfigcrio`.

The host computer communicates with the cRIO-9082 over a standard Ethernet connection.

## Configuring IP Settings and Installing LabVIEW Real-Time Software

---

This section describes how to configure IP settings and install LabVIEW Real-Time software on the cRIO-908x. If your system has a version of Windows installed on it, refer to the

Windows documentation for information about configuring IP settings. Systems shipped with Windows pre-installed also have a compatible version of the NI-RIO software pre-installed.

When you power on the controller for the first time, it boots into safe mode if there is no software installed on it. Complete the following steps to configure IP settings and install software.

1. Power on the system with the DISABLE RT DIP switch in the OFF position.
2. Launch MAX on the host computer and expand **Remote Systems** in the MAX configuration tree. MAX lists the cRIO controller as the model name of the controller followed by the MAC address, for example, **NI-cRIO-908100802f108562**.

The controller automatically attempts to connect to the network using DHCP. If the controller is unable to obtain an IP address, it connects to the network with a link-local IP address with the form `169.254.x.x`.

3. Enter a name for the Real-Time target in the Name field in the System Settings tab.
4. Select the controller under Remote Systems to see the Network Settings tab in the middle pane of MAX.
5. Select settings for the Real-Time target in the IP Settings section, then click Apply.



**Note** For information about configuring network settings, refer to the *Configuring Network Settings* book of the *MAX Remote Systems Help*. In MAX, click **Help»Help Topics»Remote Systems**. On the Contents tab, browse to **LabVIEW Real-Time Target Configuration»Configuring Network Settings**.

6. When you click **Apply**, you are prompted to reboot the controller for the changes to take effect. Click **Yes**. You can also reboot the controller by right-clicking the name under **Remote Systems** and selecting **Reboot**.
7. After rebooting, the controller appears under **Remote Systems** with the assigned name. Expand the controller and select **Software**.
8. Click **Add/Remove Software** in the toolbar to launch the LabVIEW Real-Time Software Wizard.
9. Install LabVIEW Real-Time software and device drivers on the controller.

After software installation, the controller automatically reboots. You can now program it using LabVIEW Real-Time. For information about configuring the controller to launch an embedded stand-alone application at startup, refer to the *LabVIEW Help*.

## System Reset Options

The following table lists the reset options available on the cRIO-9082. These options determine how the system behaves when the controller is reset in various conditions. Use the

RIO Device Setup utility to select reset options. Launch the RIO Device Setup utility by selecting **Start»All Programs»National Instruments»NI-RIO»RIO Device Setup**.

**Table 3.** cRIO-9082 Reset Options

<b>Chassis Reset Option</b>	<b>Behavior</b>
Do not autoload VI	Does not load the FPGA bit stream from flash memory.
Autoload VI on device powerup	Loads the FPGA bit stream from flash memory to the FPGA when the controller powers on.
Autoload VI on device reboot	Loads the FPGA bit stream from flash memory to the FPGA when you reboot the controller either with or without cycling power.

## Troubleshooting the cRIO-9082

---

### Troubleshooting Network Communication for LabVIEW Real-Time Systems

If the controller cannot communicate with the network, you can use the IP RESET switch to manually restore the controller to the default network settings. When you reboot the controller with the IP RESET switch in the ON position, the controller attempts to connect to the network using DHCP. If the controller is unable to obtain an IP address, it connects to the network with a link-local IP address with the form `169.254.x.x`.

Complete the following steps to restore the controller to the default network settings.

1. Move the IP RESET switch to the ON position.
2. Push the RESET button to cycle power to the chassis.
3. Configure the IP and other network settings in MAX from the host computer.
4. Move the IP RESET switch to the OFF position.

For more information about troubleshooting network communication, go to [ni.com/info](http://ni.com/info) and enter the Info Code `rdcriostartup`.

### STATUS LED Indicators

The STATUS LED is off during normal operation. The cRIO-9082 indicates specific software error conditions by flashing the STATUS LED yellow a certain number of times every few seconds, as shown in the following table.

**Table 4. STATUS LED Software Indicators**


<b>Number of Yellow Flashes Every Few Seconds</b>	<b>Indication</b>
1	The chassis is unconfigured. Use MAX to configure the chassis. Refer to the <i>Measurement &amp; Automation Explorer Help</i> for information about configuring the chassis.
2	The chassis has detected an error in its software. This usually occurs when an attempt to upgrade the software is interrupted. Reinstall software on the chassis. Refer to the <i>Measurement &amp; Automation Explorer Help</i> for information about installing software on the chassis.
3	The chassis is in safe mode because the SAFE MODE DIP switch is in the ON position or there is no software installed on the chassis.
4	The software has crashed twice without rebooting or cycling power between crashes. This usually occurs when the chassis runs out of memory. Review your RT VI and check the memory usage. Modify the VI as necessary to solve the memory usage issue.
Continuously Flashing	The chassis has detected an unrecoverable error. Contact National Instruments.
Continuously Flashing or Solid	The device may be configured for DHCP but unable to get an IP address because of a problem with the DHCP server. Check the network connection and try again. If the problem persists, contact National Instruments.

The cRIO-9082 indicates specific hardware error conditions by flashing the STATUS LED red a certain number of times every few seconds, as shown in the following table.

**Table 5. STATUS LED Hardware Indicators**

<b>Pattern of Red Flashes</b>	<b>Indication</b>
Continuously Flashing	An internal power supply has failed. Check front-panel I/O, CXM, and C Series module connections for shorts. Remove any shorts and power cycle the controller. If the problem persists, contact National Instruments.
Solid	The cRIO-9082 internal temperature has exceeded a critical threshold. If the problem persists, contact National Instruments.

# Where to Go Next



## Worldwide Support and Services

The NI website is your complete resource for technical support. At [ni.com/support](http://ni.com/support), you have access to everything from troubleshooting and application development self-help resources to email and phone assistance from NI Application Engineers.

Visit [ni.com/services](http://ni.com/services) for NI Factory Installation Services, repairs, extended warranty, and other services.

Visit [ni.com/register](http://ni.com/register) to register your NI product. Product registration facilitates technical support and ensures that you receive important information updates from NI.

A Declaration of Conformity (DoC) is our claim of compliance with the Council of the European Communities using the manufacturer's declaration of conformity. This system affords the user protection for electromagnetic compatibility (EMC) and product safety. You can obtain the DoC for your product by visiting [ni.com/certification](http://ni.com/certification). If your product supports calibration, you can obtain the calibration certificate for your product at [ni.com/calibration](http://ni.com/calibration).

NI corporate headquarters is located at 11500 North Mopac Expressway, Austin, Texas, 78759-3504. NI also has offices located around the world. For telephone support in the United States, create your service request at [ni.com/support](http://ni.com/support) or dial 1 866 ASK MYNI (275 6964). For telephone support outside the United States, visit the *Worldwide Offices* section of [ni.com/](http://ni.com/)

[niglobal](#) to access the branch office websites, which provide up-to-date contact information, support phone numbers, email addresses, and current events.

Refer to the *NI Trademarks and Logo Guidelines* at [ni.com/trademarks](http://ni.com/trademarks) for information on NI trademarks. Other product and company names mentioned herein are trademarks or trade names of their respective companies. For patents covering NI products/technology, refer to the appropriate location: **Help»Patents** in your software, the `patents.txt` file on your media, or the *National Instruments Patent Notice* at [ni.com/patents](http://ni.com/patents). You can find information about end-user license agreements (EULAs) and third-party legal notices in the readme file for your NI product. Refer to the *Export Compliance Information* at [ni.com/legal/export-compliance](http://ni.com/legal/export-compliance) for the NI global trade compliance policy and how to obtain relevant HTS codes, ECCNs, and other import/export data. NI MAKES NO EXPRESS OR IMPLIED WARRANTIES AS TO THE ACCURACY OF THE INFORMATION CONTAINED HEREIN AND SHALL NOT BE LIABLE FOR ANY ERRORS. U.S. Government Customers: The data contained in this manual was developed at private expense and is subject to the applicable limited rights and restricted data rights as set forth in FAR 52.227-14, DFAR 252.227-7014, and DFAR 252.227-7015.

© 2016 National Instruments. All rights reserved.

376904B-01 May16